

Oradell Fire Prevention Bureau

355 Kinderkamack Road
Oradell, NJ 07649
PH. 201-261-8200 x266 FAX 201-261-4142

Conditions for Cooking Permits

1. The permit shall be requested by and issued to the owner of the property where the event is to be held or the proprietor of the cooking operation.
2. Completed applications shall be submitted no less than 10 days prior to the date of the event.
3. No open flame-cooking device shall be permitted inside or located within 20 feet of any tent or air supported structure.
4. A site diagram shall be submitted with the permit application showing the location of the cooking operation in relation to the site with required dimensions (Diagram does not have to be to scale).
5. If LPG cylinders are used to fuel the cooking operation, all cylinders shall be properly secured to prevent falling, being knocked over and protected from tampering.
6. Portable LP-gas cooking equipment shall not be used:
 - On any porch, balcony or any other portion of a building;
 - Within any room or space of a building;
 - Within 5' of any combustible exterior wall;
 - Within 5' , vertically or horizontally, of any opening in any wall; or
 - Under any building overhang.
7. An approved fire extinguisher with a minimum rating of 20-B:C shall be provided for each cooking operation.
8. Provide a barrier to prevent access by the public to any cooking operation.
9. The location of the cooking operation shall be inspected and approved by the Fire Marshal or his designee. Time of inspection to be determined by the Fire Marshal.
10. The permit may be revoked or the cooking operation ordered closed at any time if the Fire Marshal feels that in his opinion there is a hazardous condition that may endanger the safety of the general public, any structure or violate any condition of the permit under the NJUFC.