

Oradell Fire Prevention Bureau

355 Kinderkamack Road

Oradell, NJ 07649

PH. 201-261-8200 x266 FAX 201-261-4142

Conditions for Fire Extinguisher Training

1. The permit shall be requested by and issued to the owner of the property where the training is to be held or the party responsible for providing the training.
2. Completed applications shall be submitted no less than 10 days prior to the date of the fire being set.
3. Location of training fire shall not be less than 50' from any structure/brush/shrubs/trees that may spread fire.
4. A site diagram shall be submitted with the permit application showing the location of bonfire in relation to the site with required dimensions (Diagram does not have to be to scale).
5. Material being burned shall consist only of materials that will minimize the generation and emission of air contaminants. No waste materials are permitted.
6. Containers utilized for the burning of materials shall have a screen cover to prevent the escape of embers and/or sparks.
7. At all times during any burning at least one portable fire extinguisher with a minimum rating of 4-A or two extinguishers with a 2-A rating shall be maintained available for immediate use.
8. The permit may be revoked or the fire ordered extinguished at any time if the Fire Official feels that in his opinion there is a hazardous condition that may endanger the safety of the general public or any structure.
9. Proper notification must be made to Leonia Police Headquarters at 201-944-0800 on the day of training prior to commencement and upon completion of the training.