

Oradell Fire Prevention Bureau

355 Kinderkamack Road

Oradell, NJ 07649

PH. 201-261-8200 x266 FAX 201-261-4142

Conditions for Open Burning Permit

1. The permit shall be requested by and issued to the owner of the property where the burning is to be held.
2. Completed applications shall be submitted no less than 10 days prior to the date of the fire being set.
3. Location of open burning shall be no less than 50' from any structure/brush/shrubs/trees that may spread fire. A 15' separation is permitted if fire is maintained in an approved container.
4. A site diagram shall be submitted with the permit application showing the location of fire in relation to the site with required dimensions (Diagram does not have to be to scale).
5. Material being burned shall consist only of materials that will minimize the generation and emission of air contaminants. No waste materials are permitted.
6. Containers utilized for the burning of materials shall have a screen cover to prevent the escape of embers and/or sparks.
7. At all times during any burning at least one portable fire extinguisher with a minimum rating of 4-A or two extinguishers with a 2-A rating, or other approved on-site fire extinguishing equipment (garden hose, dirt, water truck) shall be maintained available for immediate use.
8. The permit may be revoked or the fire ordered extinguished at any time if the Fire Marshal or his designee feels that there is a hazardous condition that may endanger the safety of the general public, any structure or create an objectionable situation.