

Oradell Fire Prevention Bureau

355 Kinderkamack Road
Oradell, NJ 07649
PH. 201-261-8200 x266 FAX 201-261-4142

Conditions for Torch/Flame-producing Device Permits

1. The permit shall be requested by and issued to the owner of the property or party responsible for the work.
2. Completed applications shall be submitted no less than 10 days prior to the date of the event.
3. Provide at least one portable fire extinguisher with a minimum 4-A rating, or two portable fire extinguishers with a minimum 2-A rating each, or a water hose connected to the water supply on the premises where such burning is being performed.
4. In all cases, the person doing the burning shall remain on premises, to perform a fire watch, one (1) hour after the torch or flame-producing device is utilized.
5. If LPG cylinders are used to fuel the operation, all cylinders shall be properly secured to prevent falling, being knocked over and protected from tampering.
6. The storage of LPG cylinders on roof tops shall be prohibited.

Asphalt (tar) kettles:

7. A kettle, when in operation, shall be placed a safe distance away from any structure or combustible material. Every kettle shall be equipped with a tight-fitting cover.
8. Asphalt (tar) kettles shall not be utilized inside or on the roof of any structure. Fired asphalt (tar) kettles shall not be left unattended.
9. There shall be at least one portable fire extinguisher with a minimum 20-B:C rating within 30 feet of each kettle when the kettle is in use, and an additional fire extinguisher with a minimum of 20-B:C rating on the roof being covered.

A permit may be revoked or the operation ordered stopped at any time if the Fire Official feels that in his opinion there is a hazardous condition that may endanger the safety of the general public, any structure or violate any condition of the permit under the NJUFC.